



PROFIBUS DP Slave

Pages / Attachment

1 / -

File

Rep065-1.doc

Department

Siemens PIC

Responsible

John Swindall

Signature

Lab Director or Reviewed by

Date

October 11, 2001

Customer:

AutomationDirect.Com
3505 Hutchinson Road
Cumming GA 30040

Contact Person:

Tel.:

Fax:

Name of Model: H2-PBC DL205 PROFIBUS I/O Base Controller**Manufacturer:** AutomationDirect.Com**Revision:** 1**Software Release:** Rev 1.1.11**HW Release** REV. 2**Application:** Base Controller**Ident Number:** 0608 hex**GSD-File:** AUTD0608.GSD**Minimum Slave Interval:** 0.1 ms

Solution applied:

☐ Processor☒ ASIC with processor
Designation: SPC3☐ Single Chip

Summary:

Specimen can be operated on PROFIBUS DP in conformance with the standard.
Specimen was tested according to the guidelines of the PNO, in conformance with "Test Specifications for PROFIBUS DP Slaves, Issue V2.0 February 2000".