



Test Report No. 067-1

PROFIBUS DP Slave



Pages / Attachment

1 / -

File

Rep067-1.doc

Department

Siemens PIC

Responsible

John Swindall

Signature

Lab Director or Reviewed by

Date

November 19, 2001

Customer:

AutomationDirect.Com
3505 Hutchinson Road
Cumming GA 30040

Contact Person:

Tel.:

Fax:

Name of Model: T1H-PBC PROFIBUS I/O Base Controller

Manufacturer: AutomationDirect.Com

Revision: 1

Software Release: Rev 1.1.10

HW Release: REV. A

Application: Base Controller

Ident Number: 0607 hex

GSD-File: AUTD0607.GSD

Minimum Slave Interval: 0.1 ms

Solution applied:

☐ Processor

☒ ASIC with processor
Designation: SPC3

☐ Single Chip

Summary:

Specimen can be operated on PROFIBUS DP in conformance with the standard.
Specimen was tested according to the guidelines of the PNO, in conformance with "Test Specifications for PROFIBUS DP Slaves, Issue V2.0 February 2000".